



**PROTECTIVE EQUIPMENT
TESTING LABORATORY**

Full Service High Voltage Testing

PHONE: 800-549-1477 | FAX: 620-792-2780

Email: md@petl.com Web site: www.petl.com

919 Adams Street Great Bend, KS 67530



Company: 1170 (Unique Company Number)
Company Name

Ship To:
Company Name
Shipping Address


Received By: RG
(PETL Receiving Tech)
Received: 7/29/2011
(Date Items Received at PETL)
PO: 98564
(Customer PO# (if Applicable))

Test Report

Work Order: 30868
(Test Record Number)

GLOVE

Item#	Emp#	Visual & Clean	Voltage Test			Proof Test Current	New/ Rep	Item#	Emp#	Visual & Clean	Voltage Test			Proof Test Current	New/ Rep
			Min	KV	P/R						Min	KV	P/R		
501		Pass	3.0	2.5	Pass	Pass	<input checked="" type="checkbox"/> R	502		Pass	3.0	2.5	Pass	Pass	<input checked="" type="checkbox"/> R
353		Pass	1.5	2.5	Pass	N/A		354		Pass	1.5	2.5	Pass	N/A	
301		Pass	1.5	2.5	Pass	N/A		302		Pass	1.5	2.5	Pass	N/A	
311		Pass	1.5	2.5	Pass	N/A		312		Pass	1.5	2.5	Pass	N/A	
315		Pass	1.5	2.5	Pass	N/A		316		Pass	1.5	2.5	Pass	N/A	
489		Pass	1.5	2.5	Pass	N/A		490		Pass	1.5	2.5	Pass	N/A	
453		Pass	1.5	2.5	Pass	N/A		454		Pass	1.5	2.5	Pass	N/A	
307		Pass	1.5	2.5	Pass	N/A		308		Pass	1.5	2.5	Pass	N/A	
363		Pass	1.5	2.5	Pass	N/A		364		Pass	1.5	2.5	Pass	N/A	
321		Pass	1.5	2.5	Pass	N/A		322		Pass	1.5	2.5	Pass	N/A	
499		Reject	1.5	2.5	Pass	N/A	<input type="checkbox"/>	500		Pass	1.5	2.5	Pass	N/A	<input type="checkbox"/>
391		Pass	1.5	2.5	Pass	N/A		392		Pass	1.5	2.5	Pass	N/A	
369		Pass	1.5	2.5	Pass	N/A		370		Pass	1.5	2.5	Pass	N/A	
309		Pass	1.5	2.5	Pass	N/A		310		Pass	1.5	2.5	Pass	N/A	
381		Pass	1.5	2.5	Pass	N/A		382		Pass	1.5	2.5	Pass	N/A	
357		Pass	1.5	2.5	Pass	N/A		358		Pass	1.5	2.5	Pass	N/A	



**PROTECTIVE EQUIPMENT
TESTING LABORATORY**

Full Service High Voltage Testing

PHONE: 800-549-1477 | FAX: 620-792-2780

Email: md@petl.com Web site: www.petl.com

919 Adams Street Great Bend, KS 67530



Report Summary:

Workorder# 30868

New/Replacements

<u>Number</u>	<u>RN</u>	<u>Emp</u>	<u>Item</u>	<u>L</u>	<u>Manufacturer</u>	<u>Class</u>	<u>Size</u>	<u>Length</u>	<u>Color</u>	<u>Cuff</u>
501	R		Glove	L	Salisbury	00	9	11	Yellow	Straight
502	R		Glove	R	Salisbury	00	9	11	Yellow	Straight

[Deactivated Items]

[Activated Items]

Discarded Items

Left Glove ID
N/A

Left Glove Number
N/A

Right Glove ID
N/A

Right Glove Number
N/A



**PROTECTIVE EQUIPMENT
TESTING LABORATORY**

Full Service High Voltage Testing

PHONE: 800-549-1477 | FAX: 620-792-2780

Email: md@petl.com Web site: www.petl.com

919 Adams Street Great Bend, KS 67530



Glove

Work Order: **30868**

Visual Inspection Electrical Test Summary

32	Glove Visually Inspected
1	Glove Visually Rejected
0	With Holes
1	With Snags
0	With Ozone Damage
0	With Chemical Damage
0	With Mold Defect
32	Glove Electrically Tested
0	Glove Electrically Rejected
0	Rejected Due To Voltage
0	Rejected Due To Current

Retest Billing Summary

Glove 00-2	30
Glove 3	0
Glove 4	0

New Test Billing Summary

Glove 00-2	2
Glove 3	0
Glove 4	0

IMPORTANT NOTE: All in-service Gloves are tested per ASTM F496. WARNING: Proper packaging for maximum protection on return from laboratory will be exercised. However, we cannot accept responsibility or liability for tested materials after they leave the laboratory